

Elektrakabels / Elektrabuizen / Kabelgoten FLAMRO® BK-N Brandstopkussens

Brandstopkussens



Doorvoer	Diameter (max)	Isolatie	Afdichting	Brandweerstandklasse		Goedkeurings document
				Wand	Vloer	
 Kabelgoot	geen limiet	-	FLAMRO® BK-N brandstopkussens	EI = 120	EI = 120	ETA 17/0904
 Kabels	≤ 80	-	FLAMRO® BK-N brandstopkussens	EI = 120	EI = 120	ETA 17/0904
 Kabelbundel	≤ 100 / ≤ 21	-	FLAMRO® BK-N brandstopkussens	EI = 120	EI = 120	ETA 17/0904
 Elektrabuis	≤ 16	-	FLAMRO® BK-N brandstopkussens	EI = 120	EI = 120	ETA 17/0904

Alle maten in mm

First support	≥ 100 - ≤ 600 mm	Max sparing	Wand: 600 x 600 mm
----------------------	------------------	--------------------	--------------------

Deze handleiding dient als ondersteuning voor een juiste montage.

Voor uitgebreide montage details, zie *Installation Manual of classificatierapport*

Aan deze detailtekening kunnen geen rechten worden ontleend.

Bij afwijkende situaties raadpleeg onze technische support:

 +31 10 72 71 044

 info@svt-products.nl